

No.DFS/SFO/DNH/NOC/OC/School/2003/232  
Fire Force Station,  
Dadra and Nagar Haveli,  
Silvassa, Dtd:- 24/5/2003.


C E R T I F I C A T E

Our Lady of Piety Church Trust, Silvassa has applied for grant of NOC of this department for occupancy of School building having ground + 3 at Plot No.262/4/21, 262/4/30, 262/4/31, 262/4/32 & 262/4/33 Village Silvassa as follows:

Ground floor - 06 Nos. of Class Room  
01 No. of Staff Room  
01 No. of Office  
First floor - 12 Nos. of Class Room  
Second floor - 11 Nos. of Class Room  
Third floor - 02 Nos. of Lab  
01 No. of Alunny Room

The building is having 3 nos. of staircase, front side wide passage and ground floor provided with Parking area. Since the building dose not come under the highrise category, therewould be No Objection for grant of occupancy of the School building for various Govt. approvals, subject to following condition;

1. First aid fire extinguishers bearing ISI mark shall be installed at electrical main and EACH Floor.
  2. Fire Alarm shall be installed at EACH Floor.
- Good house keeping shall be maintained at all the time in the premises.



*Station Fire Officer,*  
Station Fire Officer,  
Dadra & Nagar Haveli,  
Silvassa.

To,  
M/s. Our Lady of Piety Church Trust,  
Plot No.262/4/21, 262/4/30, 262/4/31,  
262/4/32 & 262/4/33,  
Silvassa.

For FR. AGNELO ENGLISH SCHOOL

*f. Agnelo*  
MANAGER

*f. Agnelo*  
Principal  
Fr. Agnelo English Higher Secondary School  
Silvassa-396 230.  
D&NH